



## Installation of Vulcan water treatment



**Installation site:** White Castle #38, New Jersey, USA  
**Model:** Vulcan 3000 (installed after the carbon filter bank)  
Vulcan 5000 (installed on the main inlet line)

### White Castle #38 – May 6, 2011

The Vulcan 5000 is installed on the main inlet line. The Vulcan 3000 is installed after the carbon filter bank.

The R2D2 was cleaned. A calcium crust was present at the water line before cleaning. There was a very slight indentation in the SS present at the water line.



Before Vulcan installation - scale deposits found on Pan surface.



After Vulcan installation - pan and heating element are now scale free.